

820200030 Lidl - Montgomery Village Whetstone Center

Contact: Sam Farhadi at 240 777-6333

We have reviewed site and landscape plans files:

“07-SITE-820200030-C2.01.pdf V4” uploaded on/ dated **“11/21/2019”**,
“08-LL-820200030-L2.01.pdf V4” uploaded on/ dated **“11/21/2019”** and
“08-LL-820200030-L2.02.pdf V4” uploaded on/ dated **“11/21/2019”** and

The followings need to be addressed prior to the certification of site plan:

1. Provide correct PUE width along the site frontages. The proposed PUE width is increased by the amount of PIE width where it is present.
2. Provide approved major species street trees along the site frontage on Montgomery Village Ave at the designated spacing of 50'+/- 5'. Ensure street trees will not block the line of sight at the intersections.