

JULY 28, 2021

TO

Ms. Amy Lindsey
Area 2
Maryland-National Capitol park
& Planning Commission
8787 Georgia Avenue
Silver Spring, MD 20910

RE

9808 Medical Center Drive
Lighting Certification
Site Plan Amendment 81995045G
Project No. 20200550

Dear Ms. Lindsey:

This letter is to certify that the design documents of 9800 Site Plan 81995045G conforms to the latest Illuminating Engineering Society of North America (IESNA) recommendations (Model Lighting Ordinance-MLO: June 15, 2011 or as superseded) for a development of this type. The design documents indicate all onsite exterior area lighting must be in accordance with the latest IESNA outdoor lighting recommendations (Model Lighting Ordinance – MLO: June 15, 2011 or as superseded).

All new downlights included as part of the design documents have full cut-off fixtures and deflectors will be installed on all fixtures to prevent excess illumination and glare. Private streetlights and other pole-mounted lights included in the design documents do not exceed the height illustrated on the Certified Site Plan.

Very truly yours,

EwingCole



William A.L. Gaudreau, AIA
MANAGING PRINCIPAL

DIRECT 410.837.5040